



NATIONAL TYPE EVALUATION PROGRAM

*Certificate of Conformance*  
*for Weighing and Measuring Devices*

**For:**

Weighing/Load Receiving Element  
Bench/Counter/Platform  
Model: US-E and US-i Series  
 $n_{max}$ : 5000  
 $e_{min}$ : 0.01 lb (See Below)  
Capacity: 50 to 1250 lb (See Below)  
Platform: 320 x 360 mm to 800 x 800 mm  
Accuracy Class: III

**Submitted By:**

USA Measurements  
4005 W. Reno Ave  
Suite E  
Las Vegas, NV 89118  
Tel: 800-711-2237  
Contact: Fred Herrmann  
Email: [sales@usameasurements.com](mailto:sales@usameasurements.com)  
Web site: [www.usameasurements.com](http://www.usameasurements.com)

**Standard Features and Options**

Model	Platform Size	Capacity (lb)	$e_{min}$	$n_{max}$
US-X1214	320 x 360 mm	50 /100/200	0.01/0.02/0.05 lb	5000
US-X1418	350 x 450mm	50 /100/200	0.01/0.02/0.05 lb	5000
US-X1616	400 x 400 mm	50 /100/200	0.01/0.02/0.05 lb	5000
US-X1620	400 x 500 mm	100/200/500	0.02/0.05/0.1 lb	5000
US-X1721	420 x 520 mm	100/200/500	0.02/0.05/0.1 lb	5000
US-X2424	600 x 600 mm	100/200/500/1000/1250	0.02/0.05/0.1/0.2/0.5 lb	5000
US-X2431	600 x 800 mm	500/1000/1250	0.1/0.2/0.5 lb	5000
US-X3131	800 x 800 mm	500/1000/1250	0.1/0.2/0.5 lb	5000

**Platform Material:**

- US-i Stainless Steel
- US-E Aluminum

**Load Cell Used:**

Models BT T2A non-NTEP, BT T4A non-NTEP, and BT T6B non-NTEP

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Craig VanBuren  
Chairman, NCWM, Inc.

Stephen Benjamin  
Committee Chair, NTEP Committee  
Issued: December 17, 2019

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



## USA Measurements

### Weighing/Load Receiving Element / US-E and US-I

**Application:** For general purpose weighing applications when interfaced with a certified and compatible indicating element.

**Identification:** The G.S.1 information can be found on a self-destructive label on the load receiving element under the platform.

**Sealing:** This device has no physical means that require sealing. Calibrations are performed through the indicator. Seal the indicator as required in its NTEP Certificate of Conformance.

**Test Conditions:** This Certificate of Conformance supersedes Certificate of Conformance Number 19-134 and was issued to indicate a company phone number change. No additional testing was required. Previous test conditions are listed below for reference.

**Certificate of Conformance Number 19-134:** This certificate is issued based upon the following tests and upon information provided by the manufacturer. The emphasis of this evaluation was on device design, performance, and compliance with influence factor requirements. Three US-E series were submitted to the laboratory, 400 x 400 mm (50 x 0.01 lb) 600 x 600 mm (500 x 0.01 lb) 800 x 800 mm (1000 x 0.02 lb), Several increasing/decreasing and shift tests were performed. The devices were tested over a temperature range of -10°C to 40°C (14°F to 104°F). A load of approximately one-half capacity was applied over 100 000 times. The scales were tested periodically during this time.

**Evaluated By:** E. A. Payne, Jr (MD) 19-134; M. Manheim (NCWM) 19-134A1

**Type Evaluation Criteria Used:** *NIST Handbook 44 Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices*, 2012 Edition. *NCWM Publication 14 Measuring Devices*, 2012 Edition.

**Conclusion:** The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

**Information Reviewed By:** D. Flocken (NCWM) 19-134, 19-134A1

**Example(s) of Device:**

